

**Building Renewal Grant Application**

**Initial Submission Date:**

**Application ID:** 431

**Resubmittal Date:**

Please provide as much of the requested information as possible. SFB staff will assist in developing required information that is not currently available.

**District Name:** Scottsdale Unified District  
**Superintendent:** David Peterson  
**Contact Person:** Carlos Monreal  
**Contact Phone Number:** 4804848519  
**Contact Email:** cmonreal@susd.org  
**School Site:** Coronado High School  
**Buildings:** 9999 School Wide

**Description of Problem**

Please include a detailed description of the issues, as well as a description of and a copy of any professional studies, citations or reports from government entities, recommended solutions, and any cost information or estimates. If additional space is needed, please attach.

York 750 ton chiller 5to7 years old has a worn out shaft seal and it must be replaced, the following is the scope of work:  
Lock out and tag out chiller.  
Isolate compressor and move refrigerant to condenser.  
Remove motor coupling.  
Remove defective shaft seal and dispose.  
Provide and install new OEM Shaft seal. Part # 029-22454-000  
Install new O-rings  
Evacuate chiller and reinstall customer's refrigerant.  
Restart chiller and check operation  
The cost of repair from EMCOR one of our pre-procured vendors is \$10,995.00

**Project Category:** HVAC

**Are any of the above-described issues in buildings or part of buildings that are leased to another entity, including a district sponsored charter school? ?**

**Available Funding**

Current unencumbered building renewal fund balance (Fund 690):	\$0.00
Amount of Local funds planned for this project	\$0.00

Please outline any associated insurance coverage.

## Building Renewal Grant Application

**Liaison:** Cruse

pcruse@azsfb.gov

602-364-1193

---

Superintendent Printed Name

---

Superintendent Signature

---

Date